



Certificate of Compliance

Certificate: 80028771

Master Contract: 601104

Project: 80028771

Date Issued: 2019-12-31

Issued to: TSUNESS Co., Ltd.
Building E1, No.555, Chuangye Road,
Dayun town, jiashan Country,
jiaxing, Zhejiang, 130 314100
China

Attention: Chenyang Pei

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Yang (Jason) Lei
Yang (Jason) Lei

PRODUCTS

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Utility Interactive Inverter, Model TSOL-M1600, TSOL-M800, TSOL-M400 and TSOL-M350, rack mounted.

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

*Note: This product is PV Rapid Shut Down Equipment and conforms with NEC-2014 and NEC-2017 Article 690.12 and CEC-2018 Sec 64-218 Rapid Shutdown of PV Systems, for AC and DC conductors, when installed According to manufacturer's instructions.



Certificate: 80028771

Master Contract: 601104

Project: 80028771

Date Issued: 2019-12-31

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 107.1-16 - Power Conversion Equipment

*UL Std. No. 1741 - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Second Edition, Revision dated February 15, 2018)

*Note: Conformity to UL 1741-Second Edition (February 15, 2018) includes compliance with applicable requirements of IEEE 1547-2003(R2008) , IEEE 1547.1-2005 (R2011).